



CROSS - SECTION

CLASS A LONGITUDINAL SECTION




CROSS - SECTION

CLASS B LONGITUDINAL SECTION



CROSS - SECTION

CLASS C LONGITUDINAL SECTION



CROSS - SECTION

CLASS D LONGITUDINAL SECTION


NOTE: PIPE SHALL NOT BE SUPPORTED BY BELLS. PIPE SHALL LAY FLAT ON TRENCH BOTTOM.

STANDARD BEDDING DETAILS

NOT TO SCALE

I.D. PIPE	STANDARD TRENCH WIDTH
2" - 12"	30"
14" - 18"	36"
20" - 24"	42"
26" - 30"	54"
32" - 36"	60"
38" - 42"	66"
44" - 48"	72"
50" - 54"	78"
56" - 60"	84"

STANDARD TRENCH WIDTH



CONCRETE ENCASMENT

NOT TO SCALE

The City of Enid
401 West Owen St. Contact Room
Enid, Oklahoma 73702
Telephone: (800) 233-0660 Fax: (800) 234-8848

CONTACTS:

Robert Hill, Director of Engineering Services, Ext. 344
Adam Stroup, Civil Engineer, Ext. 349



The City of Enid, Oklahoma

REVISIONS	
Number	Description

Project Number:	
Project Location:	

Sheet Title:	STANDARD SANITARY SEWER BEDDING DETAIL
Project Title:	

Engr. Seal

Date:	6/1/00
Scale:	NO SCALE
Cad File:	c:\DATA\SPES\SWBDS
Drawn By:	P.B./C.L.H.
Designed By:	R.H.
Approved By:	R.H.
Sheet:	of